


Installation Instructions

Holywell Plug & Play Batten

Dimensions:

Part No.	Description	L (mm)	W (mm)	H (mm)	LF (mm)	Weight
431300	Holywell Plus 14W/20W 4ft Single	1203	64	66	880	1.4Kg
431301	Holywell Plus 21W/30W 4ft Twin	1203	64	66	880	1.4Kg
431302	Holywell Plus 14W/20W 5ft Single	1503	64	66	1180	1.7Kg
431303	Holywell Plus 28W/40W 5ft Twin	1503	64	66	1180	1.7Kg
431304	Holywell Plus 21W/30W 6ft Single	1803	64	66	1480	1.9Kg
431305	Holywell Plus 32W/50W 6ft Twin	1803	64	66	1480	1.9Kg



End Of Life Disposal:


Disassembly instructions for end of life disposal available on website.
Disposal of Electronic Equipment WEEE Directive 2002/96/EC This product falls within the scope of the Waste Electrical & Electronic Equipment Directive (WEEE), which means the product should not be disposed of as normal household waste. Please recycle where facilities exist or check with your Local Authority. RoHS - All components and materials used in this product are RoHS 2002/95/EC compliant. Specifications may change from time to time. The information contained in this leaflet is for guidance only and should not be considered as always accurate and should be treated as not representative.

Input	220-240V AC
Power	14-20W/21-30W/28-40W/32-50W
Operating Temp	0°C–+40°C
Connection Type	Push Fit Terminal
Emergency Option	430962 (Sold Separately)
Control Connection	430916 (Sold Separately)
Light Source Energy Rating	B



Box Contents:

- Holywell Batten
- Fixing Kit



Tools Required For Installation:

- Wire Strippers / Cutters
- Screwdriver
- Drill



READ THESE INSTRUCTIONS THOROUGHLY BEFORE INSTALLATION
KEEP THESE INSTRUCTIONS FOR FUTURE REFERENCE.

IMPORTANT:

This product must be installed by a qualified electrician or competent person, and in accordance with current building and IET wiring regulations.

Warranty:

This luminaire is warranted for a period of 5 Years from the date of purchase**. The warranty could be invalidated should the light fitting not be installed according to these instructions, outside the scope of the specification or the product has been altered or tampered with in any way. Please see website for terms and conditions.



WARNING: Risk of electric shock!


Isolate the mains power before proceeding.

- Turn off the mains power before performing inspections, installation, or removal
- Verify that the supply voltage is correct by comparing it with the luminaire label information
- It is the installers responsibility to ensure installation is suitable for the total load of the luminaire(s). The supply cable, fuses/circuit breakers must be correctly rated for the electrical load and considering for any transient inrush currents that may occur.
- Do not perform insulation strength or resistance tests on installed luminaire(s) connected


Installation Procedure:

1. Disconnect the mains supply.
2. Install the batten in desired location.
3. Connect mains to terminal block as indicated—Standard version.
4. Connect mains to terminal block as indicated—Emergency version.
5. Select required wattage via dip-switch on LED driver.
6. Re-fit the diffuser and use screws provided to secure into position.
7. Reconnect the mains supply.

1.




2.




3.

Electrical connection wiring




4.

EMERGENCY FITTINGS ONLY. EARTH CONNECTION REQUIRED.



5.

Higher Wattage ON Lower Wattage



6.

